



Lincoln Street Well POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN MONTHLY

(As required if initial monthly sampling is over 10 ppt and under 20 ppt)

Lincoln Street Well POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
1/6/2021 (Exploratory Sample)	14.50
10/13/2021 (AA)	18.25
11/4/2021 (AA)	18.87
12/21/2021 (AA)	19.79
1/11/2022 (AA)	19.32
2/10/2022 (AA)	16.66
2/10/2022 (NECC)	10.54
3/8/2022 (AA)	20.07
3/8/2022 (NECC)	14.24
4/7/2022 (AA)	18.62
4/7/2022 (NECC)	10.22
5/10/2022 (AA)	17.90
5/10/2022 (NECC)	11.68
6/7/2022 (AA)	17.64
6/7/2022 (NECC)	11.46
7/7/2022 (AA)	18.26
7/7/2022 (NECC)	10.86
8/15/2022 (AA)	16.7
8/15/2022 (NECC)	11.4

Note: Split sampling began in February 2022 as lab results were known to vary.



Lincoln Street Well POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN MONTHLY

(As required if initial monthly sampling is over 10 ppt and under 20 ppt)

Lincoln Street Well POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
9/8/2022 (AA)	17.20
9/8/2022 (NECC)	12.40
10/5/2022 (AA)	15.30
10/5/2022 (NECC)	10.80
11/1/2022 (AA)	15.30
11/1/2022 (NECC)	10.40
12/6/2022 (AA)	15.2
12/6/2022 (NECC)	10.5
1/6/2023 (AA)	18.5
1/6/2023 (NECC)	15.5
2/7/2023 (NECC)	11.59
3/9/2023 (NECC)	16.71
4/6/2023 (NECC)	10.88
5/2023 (NECC)	12.27
6/2023 (NECC)	11.11
7/2023 (NECC)	12.27
8/2023 (NECC)	10.63
9/13/2023 (NECC)	9.69

Note: Split sampling began February 2022 through January 2023 as lab results were known to vary. The Town will use one sample from February 2023 on.



Lincoln Street Well POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN MONTHLY

(As required if initial monthly sampling is over 10 ppt and under 20 ppt)

Lincoln Street Well POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
10/04/2023 (NECC)	7.58
11/14/2023 (NECC)	8.91
12/10/2023 (NECC)	11.3
1/11/2024 (NECC)	13.01
2/14/2024 (NECC)	16.11
3/12/24 (NECC)	15.21
4/5/24 (NECC)	16.63
5/8/24 (NECC)	10.93
6/4/24 (NECC)	12.10
7/9/24 (NECC)	13.97
8/6/24 (NECC)	14.26
9/10/24 (NECC)	13.40
10/2/24 (NECC)	14.46
11/6/24 (NECC)	15.01
12/11/24 (NECC)	14.93
1/14/25 (NECC)	14.19
2/11/25 (NECC)	16.54

Note: Split sampling began February 2022 through January 2023 as lab results were known to vary. The Town will use one sample from February 2023 on.



Gravelly Pond POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN QUARTERLY AND MONTHLY AS OF MAY 2023
(As required if initial sampling is under 10 ppt.)

Gravelly Pond POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
10/13/2021 (AA)	7.35
11/4/2021 (AA)	7.24
1/11/2022 (AA)	6.80
4/7/2022 (AA)	6.72
4/7/2022 (NECC)	2.94
7/7/2022 (AA)	7.89
7/7/2022 (NECC)	2.81
12/9/2022 (AA)	7.65
12/9/2022 (NECC)	3.25
4/6/2023 (NECC)	3.27
5/2023 (NECC)	3.73
6/2023 (NECC)	3.59
7/2023 (NECC)	4.06
8/8/2023 (NECC)	3.47
9/13/2023 (NECC)	5.49
10/04/2023 (NECC)	2.46
11/14/2023 (NECC)	3.49
12/10/2023 (NECC)	3.25
1/11/2024 (NECC)	3.03

Note: Split sampling began in February 2022 as lab results were known to vary.
The Town will use one sample from February 2023 on.



Gravelly Pond POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN QUARTERLY AND MONTHLY AS OF MAY 2023
(As required if initial sampling is under 10 ppt.)

Gravelly Pond POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
2/14/2024 (NECC)	6.27
3/12/24 (NECC)	6.06
4/5/24 (NECC)	7.06
5/8/24 (NECC)	2.42
6/4/24 (NECC)	5.07
7/9/24 (NECC)	5.49
8/6/24 (NECC)	5.60
9/10/24 (NECC)	6.08
10/2/24 (NECC)	7.25
11/6/24 (NECC)	6.72
12/11/24 (NECC)	6.94
1/14/25 (NECC)	6.94
2/11/25 (NECC)	6.51

KEY:

AA - Alpha Analytical Lab

NECC - New England ChromaChem Lab

PPT - Parts per Trillion

POE/FW - Point of Entry/Finish Water