



Available Fire Flow Manchester by the Sea, Massachusetts



TATA & HOWARD

Approximate Scale: 1" = 750'
July 2023

The estimated available fire flows are not a guarantee of hydrant capacity and are dependent on the system conditions.
Gravelly Pond Water Treatment Plant on at a flow rate of 1,000 gpm.
Lincoln Street Well on at a flow rate of 350 gpm.
Moses Hill Standpipe Water Elevation of 268 feet.
2020 Maximum Day Demand of 1.40 mgd.